

## Facility Summary in GOLDEN VALLEY County in the City of LAVINA

**Location:** FARMERS UNION TRADING CO - LAVINA  
4666 MT HIGHWAY 3  
LAVINA, MT 59046 GOLDEN VALLEY

**Sys Fac ID:** 19-13681

**Last Inspected On:** 9/19/2013

**Operating Permit Renewal Date:** 10/24/2016

**Contact:** Sid Boe, (406) 636-4005

**Owners/Operators:** Farmers Union Trading Co Columbus, Owner (406)-322-5618 PO BOX 509  
COLUMBUS MT 59019-0509

Sid or Quint Boe, UST Class A Operator  
Sonia Hollingsworth, UST Class A Operator  
Nathanial Williams, UST Class A Operator  
Sid or Quint Boe, UST Class B Operator  
Sonia Hollingsworth, UST Class B Operator  
Sonia Hollingsworth, UST Class B Global Operator  
Nathanial Williams, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	19	3/1/1996	Unknown	Flexible Plastic	
<b>3381</b>	Yes	10/16/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
10,000					
2	19	3/1/1996	Unknown	Flexible Plastic	
<b>3382</b>	Yes	10/16/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
10,000					

## Facility Summary in GOLDEN VALLEY County in the City of RYEGATE

**Location:** RYEGATE PUBLIC SCHOOLS DIST 1  
207 2ND AVE W PO BOX 129  
RYEGATE, MT 59074 GOLDEN VALLEY

**Sys Fac ID:** 19-07975

**Last Inspected On:** 2/15/2013

**Operating Permit Renewal Date:** 6/4/2016

**Contact:** Loren Higgins, (406) 568-2211

**Owners/Operators:** School Dist 1 Ryegate, Owner (406)-568-2211 PO BOX 129  
RYEGATE MT 59074-0129

Thomas Bracha, UST Class A Operator

Penny Stradtman, UST Class A Operator

Thomas Bracha, UST Class B Operator

Penny Stradtman, UST Class B Operator

Thomas Bracha, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	19	8/1/1996	Bare Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
1870	Yes	7/31/2014	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
5,000		7/31/2014	TLS-300 , Veeder Root		

## Facility Summary in GOLDEN VALLEY County in the City of RYEGATE

**Location:** SUPER D GROCERY  
203 E RAILWAY AVE  
RYEGATE, MT 59074 GOLDEN VALLEY

**Sys Fac ID:** 19-13735

**Last Inspected On:** 9/22/2015

**Operating Permit Renewal Date:** 12/10/2018

**Contact:** Super D, (406) 568-2378

**Owners/Operators:** Super D Grocery Inc, Owner (406)-568-2378 PO BOX 170  
RYEGATE MT 59074  
Super D Grocery Inc, Operator (406)-568-2378 PO BOX 170  
RYEGATE MT 59074  
Peggy Sutton, UST Class A Operator  
Peggy Sutton, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	19	4/8/1996	Unknown	Flexible Plastic	High Level Alarm
<b>3462</b>	Yes		None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
2	17	12/1/1998	Unknown	Flexible Plastic	High Level Alarm
<b>3727</b>	Yes		None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	
3	17	12/1/1998	Unknown	Flexible Plastic	High Level Alarm
<b>3728</b>	Yes		None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			Gilbarco EMC Basic , Gilbarco	Continuous Interstitial Monitor	